

Utah Department of Environmental Quality

Division of Drinking Water

Public Water System Inventory Report

Run Date:
08/04/2011 12:11 pm

PWS ID: UTAH14029 **Name:** SHILOAH WELLS WATER CO
Legal Contact: SHILOAH WELLS WATER CO **Rating:** Approved
DEAN G HAYWARD **Rating Date:** 08/03/1987
Address: 1100 CIRCLE DR **Activity Status:** Active
ESKDALE, UT 84728
Phone Number: 801-265-3883
City Served (Area):
County: MILLARD COUNTY
System Type: Community **Last Inv Update:** 01/18/2008 **Avg Daily Prod:**
Activity Status Cd: Active **Last Snty Srv Dt:** 11/16/2010 **Total Dsgn Cap:**
Population: 85 **Surveyor:** WADE TOLBERT **Total Emerg Cap:**
Oper Period: 1/1 to 12/31

Gal/Day Gal/Min

Contacts

Contact Type	Name	Title	Phone Numbers		Email Address
			Office	Emergency	
AC	HAYWARD, DEAN G		801-265-3883	435-855-2143	deangh@ix.netcom.com

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Residential	Unmetered	0	27
			27 Total Svc Connections

Storage

Total Storage: 15,000 GAL **Number of Units:** 1 **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matrl	Overflow Elev	Activity Status	Press'd
ST001	SHILOAH WELLS TANK	Ground	15,000 GAL	Steel		A	NO

Pumping Stations

Facility No	Facility Name	Activity Status	Capacity	Avail	Emerg Power	Operating Category	Total Dynamic Head
PF001	SHILOAH WELLS BOOSTER	A		P			

Distribution System

Pump Type	Total Dyn Head ft H2O P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No				

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	SHILOA WELL 1	Inactive	WL	12	200 GPM		Yes	GW	Other		
WS002	1993 WELL 2	Active	WL			800 GPM	Yes	GW	Permanent	1/1 to 12/31	

*Reports measured flow for wells, approved design capacity for all other sources.